

sensus PolluCom E

Err 40 10 ▲	Error message (only in case of error)
* 28053 mWh	Accumulated heat and/or chill energy
14823 mWh 3 11204 °C	Target day consumption incl. corresponding date *
* 895923 m ³	Accumulated volume *
00000000 GJm/ mWh *▲▲▲▲▲▲▲▲	Segment test
2813 mWh (28)	Tariff consumption 1 * (if activated)
* 7053 mWh C	Tariff consumption chill * (if activated)
15230,123 m ³ ▲▲	Consumption pulse meter1* (optional)
116890,123 m ³ ▲▲	Consumption pulse meter2* (optional)
* 253 m ³ / h	Instantaneous flow *
* 29053 kW	Instantaneous energy *
°C 69,3	Temperature in warmer pipe *
°C 48,2	Temperature in colder pipe *
▲ 2 1098	Temperature difference *
12345678 CL IEnt	Customer's reference number *

hlášení chyby

(zobrazí se pouze v případě chyby)

aktuální hodnota tepla

odečet tepla

(zobrazí se společně s datem odečtu)

aktuální hodnota objemu

test segmentů

